



### Agenda Item Details

---

Meeting	Oct 27, 2014 - Regular Meeting
Category	7. Consent Agenda
Subject	7.11 ITB 15-07 Emergency Bid for Electrical Wire Replacement-Ruckel, presented by Vince Windham, Program Director, Purchasing, and recommended by the Superintendent for approval.
Access	Public
Type	Action (Consent)
Fiscal Impact	Yes
Dollar Amount	32,754.00
Budgeted	Yes
Budget Source	Capital Funds, Project 2336, Emergency Maintenance-District Wide
Recommended Action	Motion to approved the committee's recommendation to award the Emergency Bid for Electrical Wire Replacement at Ruckel Middle School to Bearden Construction Company, Inc. in the amount of \$32,754.00. The amount of \$26,854.00 for wire replacement and \$5,900.00 for the option to replace the conduit, if needed. Emergency Bid procedures per School Board Policy 2-17(A)(13) were used for this solicitation due to the following: Ruckel Middle School lost power to part of the campus on Wednesday, October 8, 2014. The Maintenance Department discovered conductors that pose a potential to short out a 400 amp feed to one (1) of the ramps at Ruckel. What caused the electrical splice to deteriorate is unknown. What is known is that it should not have occurred. One (1) of the four (4) 600 MCM Aluminum conductors shorted out and overheated causing the outage. The damaged conductor is still alive and overheating is damaging the conductor it is laying on in the underground manhole. They could short out at any time and we would have to rent a generator to run that portion of the school until the new conductors are installed. Funding will be paid from Capital funds, Project 2336, Emergency Maintenance-District Wide. A copy of the tabulation is attached.

### Public Content

---

Request approval of the committee's recommendation to award the Emergency Bid for Electrical Wire Replacement at Ruckel Middle School to Bearden Construction Company, Inc. in the amount of \$32,754.00. The amount of \$26,854.00 for wire replacement and \$5,900.00 for the option to replace the conduit, if needed. Emergency Bid procedures per School Board Policy 2-17(A)(13) were used for this solicitation due to the following: Ruckel Middle School lost power to part of the campus on Wednesday, October 8, 2014. The Maintenance Department discovered conductors that pose a potential to short out a 400 amp feed to one (1) of the ramps at Ruckel. What caused the electrical splice to deteriorate is unknown. What is known is that it should not have occurred. One (1) of the four (4) 600 MCM Aluminum conductors shorted out and overheated causing the outage. The damaged conductor is still alive and overheating is damaging the conductor it is laying on in the underground manhole. They could short out at any time and we would have to rent a generator to run that portion of the school until the new conductors are installed. Funding will be paid from Capital funds, Project 2336, Emergency Maintenance-District Wide. A copy of the tabulation is attached.

For additional information, please contact Steve Bolton, Program Director, Maintenance at (850) 689-7159.

[EMERGENCY BID-ITB 15-07.pdf \(80 KB\)](#)

## **Administrative Content**

---

*Our adopted rules of Parliamentary Procedure, Robert's Rules, provide for a consent agenda listing several items for approval of the Board by a single motion. Documentation concerning these items have been provided to all Board members and the public in advance to assure an extensive and thorough review. Items may be removed from the consent agenda at the request of any board member.*

## **Motion & Voting**


---

Motion to approve the Consent Agenda and all of the Consent Agenda items as recommended by the Superintendent

Motion by Cathy Thigpen, second by Cindy Frakes.

Final Resolution: Motion Carries

Yes: Dewey Destin, Cindy Frakes, Cathy Thigpen, Melissa Thrush, Rodney Walker



TABULATION AND RECOMMENDATION FOR ITB 15-07 EMERGENCY BID FOR ELECTRICAL WIRE REPLACEMENT - RUCKEL MIDDLE SCHOOL.

Item No	Description	QTY	Peaden	Bearden Construction Co.	Bayou Mechanical
1	Provide and install a new feed consisting of 4 runs of 600 XHHW Aluminum and 1 run of #2 THHN2 copper in existing conduit - appx 535'; Termination of new feeds; Remove existing conductors/debris and dispose of conductors & debris; Work to begin on 10/17/14 and job to be completed and up and running prior to start of school on 10/21/14 provided no unforeseen issues; Electrical permit included.		\$28,650.00	\$26,854.00	No Bid
	Option #1: Provide 115KW Generator, Price Per Day		\$1,470.00 per Day	\$2,400.00 per day	No Bid
	Option #2: Replace 200' of 3.5" conduit if required		\$5,730.00	\$5,900.00	No Bid
	Completion Time:		No later than 10/20/14	No later than 10/20/14.	No Bid

Offers from the vendors listed herein are the only offers received timely as of the above opening date and time. All other offers submitted in response to this solicitation, if any are hereby rejected as late.

**BIDDERS WHO BID "NO BID":** None  
**NON-RESPONSIVE BIDDERS:** None

TABULATION AND RECOMMENDATION FOR ITB 15-07 EMERGENCY BID FOR ELECTRICAL WIRE REPLACEMENT - RUCKEL MIDDdle SCHOOL.

**RECOMMENDATION FOR AWARD:**

Committee: Steve Bolton, Maintenance Dept

Bill Smith, Facilities

Committee recommends award to the lowest responsible and responsive bidder Bearden Construction Company, Inc. in the amount of \$26,854.00 for wire replacement and \$5,900.00 (Option to replace conduit if needed). District intends to rent a generator on a daily basis if option to replace conduit is needed.


**FUNDING**

<u>Fund</u>	<u>Function</u>	<u>Object</u>	<u>Center</u>	<u>Project</u>	<u>Amount</u>	
3715	7400	0684	9025	2336	\$32,754.00	Emergency Maintenance

"Failure to file a protest within the time prescribed in Florida Statutes 120.57, Florida Statutes, shall constitute a waiver of proceedings under Chapter 120, Florida Statutes."

Emergency Bid procedures per School Board Policy 2-17(A)(13) were used for this solicitation due to the following: Ruckel Middle School lost power to part of the campus on Wednesday, October 8, 2014. The Maintenance Department discovered conductors that pose a potential to short out a 400 amp feed to one of the ramps at Ruckel. What caused the electrical splice to deteriorate is unknown. What is known is that it should not have occurred. One of the four 600 MCM Aluminum conductors shorted out and overheated causing an outage. The damaged conductor is still alive and overheating is damaging the conductor it is laying on in the underground manhole. They could short out at any time and we would have to rent a generator to run that portion of the school until new conductors are installed.

Approval of Emergency Bid Award:

  
\_\_\_\_\_  
Superintendent of Schools

Posted: 10/14/14 2:00 PM CT

# Bearden Construction Company, Inc.



**ELECTRICAL CONTRACTORS**

**Industrial**

**Commercial**

**Pole Line**

October 14, 2014

To: Okaloosa School District, Tom Cox and Luke Mitchell  
Ref: Ruckel Middle School-Niceville Emergency Wire Replacement

Gentlemen,

Bearden Construction Company, Inc. E.C. is pleased to provide our quote on the electrical portion of the above referenced project per the attached scope of work and our pertinent notes.

Item #1: Wire Replacement:	\$ 26,854.00
Item #2: Add Option #1 Temporary Genset Connection per day:	\$ 2,400.00
Item #3: Add Option #2: Ditching and Re-place Duct:	\$ 5,900.00

The following notes apply.

1. Our quote is in accordance with the attached scope of work provided.

If you have any questions please call Gary Bearden or the undersigned.

Thank you,

Earl Bearden, C.E.O.

Via fax or e-mail 2-pages



Telephone: 850-863-2131 • P.O. Box 849 • Fort Walton Beach, Florida 32549/0849  
Fax # 850-863-2136 • E-mail: Richard@beardenelectric.com • State Cert. Elect. Contr. #EC0000327